



## Certificate of Compliance

### LATICRETE SpectraLOCK 2000 IG

#### Laticrete International

In addition to meeting the GREENGUARD Children & Schools Certification Criteria, this product complies with CA Section 01350 Version 1.1, including the 2012 update for formaldehyde at 9  $\mu\text{g}/\text{m}^3$  (office seating  $\leq 4.5 \mu\text{g}/\text{m}^3$ ).

#### Certification Details:

**Certificate No:** 9553-420

**Status:** Certified

**Period:** 01/2010 - 12/2012

**Restrictions:** NONE

**Reference Standard:** GGPS.002 GREENGUARD Children & Schools<sup>SM</sup> Standard

**Product Type:** All Products

Criteria	Allowable Limits
Individual VOCs <sup>1,2</sup>	$\leq 1/100$ TLV and $\leq 1/2$ CA CREL (Office Seating $\leq 1/100$ TLV and $\leq 1/4$ CA CREL)
Formaldehyde	$\leq 0.0135$ ppm / 13.5 ppb (Office Seating $\leq 0.00675$ ppm / 6.75 ppb)
TVOC <sup>3</sup>	$\leq 0.22 \text{ mg}/\text{m}^3$
Total Aldehydes	$\leq 0.043$ ppm / 43 ppb
Total Phthalates	$\leq 0.01 \text{ mg}/\text{m}^3$
Total Particles <sup>4</sup>	$\leq 0.02 \text{ mg}/\text{m}^3$

See referenced standard for a complete technical explanation.

<sup>1</sup> Any VOC not listed must produce an air concentration level no greater than 1/100 the Threshold Limit Value (TLV) industrial work place standard (Reference: American Conference of Government Industrial Hygienists, 6500 Glenway, Building D-7, Cincinnati, Ohio 45211-4438) and no greater than 1/2 the CA Chronic Reference Exposure Level (CREL) [http://www.oehha.ca.gov/air/chronic\\_rels/AllChrels.html](http://www.oehha.ca.gov/air/chronic_rels/AllChrels.html) (Adopted by the State of California Office of Environmental Health Hazard Assessment (OEHHHA), December 2008).

<sup>2</sup> 1-Methyl-2-Pyrrolidinone must be  $\leq 0.08 \text{ mg}/\text{m}^3$  for office seating and  $\leq 0.16 \text{ mg}/\text{m}^3$  for all other product types.

<sup>3</sup> Defined to be the total response of measured VOCs falling within the C<sub>6</sub>-C<sub>16</sub> range, with responses calibrated to a toluene surrogate.

<sup>4</sup> Particles are only applicable to fibrous, particle-releasing products with exposed surface area in air streams.

Seating, Workstations and Casework Systems comply with ANSI/BIFMA e3-2011e Credit 7.6.2. Workstations have been evaluated and show compliance in the the Open Plan and Private Office Environments. Casework systems have been evaluated and show compliance in the Private Office Environment. Seating shows compliance in the BIFMA seating environment for office chairs and the CDPH classroom for student seating. Educational furniture is evaluated in the CDPH classroom environment.

Complies with California Department of Public Health "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers, Version 1.1" (CA Section 01350).

GREENGUARD Certification affirms that representative samples of the products tested meet the criteria of the referenced standards and the requirements of the specific certification program. Certification testing is conducted according to a consistent, defined protocol. It does not measure emissions under usage conditions other than those defined in the protocol and does not address potential environmental impact other than chemical emissions.

The GREENGUARD Environmental Institute (GEI) is an independent, third-party certification organization that qualifies products for low chemical emissions. GREENGUARD certification programs use defined product standards, test methodologies, product sample collection and handling procedures, testing types and frequencies, program application processes, and on-going verification procedures. GREENGUARD standards, methods, and procedures are available at [www.GREENGUARD.org](http://www.GREENGUARD.org).